TACWA

November 15, 2019

Partnership to Renew Lake Arlington Raw Water Pump Stations: Shared Operations Improvements Justin Kirchdoerfer, P.E. – Arlington Water Utilities John Logan, P.E. – Trinity River Authority of Texas

















Shared Operations Improvements

Two Owners in partnership using one site to serve two areas One Project with combined designed efforts



Different Operational Requirements

means closer coordination is


needed

Shared Operational Considerations

affects both parties Combined Procurements expedite the process

TCWPS RWPS and LARWPS – PS Locations





Partners: Arlington Water Utility (AWU)

City Water Utility

Service Area

Raw Water and Treated Facilities


- **★** LARWPS (1974)
 - Multi-Level Intake
- ***** Pierce-Burch WTP
- ★ John F. Kubala WTP

Arlington City Council

Existing LARWPS

The existing PS was constructed in 1974. The facility will be configured with pumps to provide needed capacity for both AWU and TRA.









Partners: Trinity River Authority (TRA)


River Authority

Service Area – North Region

Raw Water and Treated Facilities

- TCWSP RWPS (1957)
 - Single Level Intake
- TCWSP WTP

Board of Directors



Existing TCWSP RWPS

The existing PS was constructed in 1957.










<u>Project</u> <u>History</u> A Recipe for Partnership	Location Both existing pump stations are about 600 LF apart	Required Maintenance Several upgrades over four and six decades, respectively
 Drivers LARWPS capace AWU needs Extend service life additional 25 yea Improve O&M cost Increase redundation 	te for another ars sts and protocols	02 03 04
	Cost Estimate Renovation for shared usage is approximately \$20 M	Interlocal Agreement AWU and TRA will jointly use, operate and maintain the PS

Upgrades Needed Both existing pump stations require upgrades to their pumps, electrical gear, and support systems


Partnership – Proposed Improvements

- ★ Pump Improvements
 - Three dedicated pumps for each Owner
 - AWU: Firm Fixed Capacity = 80 MGD
 - TRA: Firm Fixed Capacity=97 MGD
 - Shared Discharge Header Isolated by BFV
- ★ Electrical Improvements
 - VFDs, SWGR, Primary Service on Transformers, Redundancy, Main-Tie-Main
 - Electrical Building Extension
 - Common instruments, separate SCADA feeds
- **†** Piping Improvements
 - New yard pipe with connections along dam
- Zebra Mussel
 - Planning for zebra mussel mitigation




Game-Changing Tool

Improving conceptual design with better understanding and recording of existing condition through Matterport.



Improving Design with Quality Photos




From Matterport to Revit Visualizing Design

MATTERPORT | EXISTING PUMPS LINE UP

REVIT | PROPOSED PUMPS LINE UP







TRA PUMPS AND WATER QUALITY PANELS



Copper Based Molluscicide





(

Utilized in pipe for taste and odor

Ability to protect pump station



Operational flexibility

PUMP STATION WALKTHROUGH



AWU PUMPS AND IRRIGATION




Hydraulic Modeling Wet Well Considerations



Physical Model at Alden Labs

- 6 Pumps
 - 3 x 48 MGD
 - 3 x 40 MGD

Additional Owner Coordination Items



Physical Security and Permanent Site Access

*

Communications and SCADA


Pipeline Along Dam

*

Raw Water Pipe System Interconnection and Operation During Construction

Chemical Usage

Additional Owner Coordination Items




Documenting Ownership Primary Electrical Service from Utility

Redundant Transformers

Surge Modeling

Relocating Backup Power Generation

Procurement Strategy



Schedule Schedule is time-sensitive Operational Constraints Work required to be done during lowdemand periods

Pre-Purchase AWU pumps were pre-purchased to expedite schedule CSP Allows selected offeror to negotiate scope or time modifications

