


Texas Association of Clean Water Agencies
September 22, 2017

NTMWD's Approach to Long-Term Water Resource Recovery Planning

Shela Chowdhury, PE/NTMWD and Mia Welch, PE/CH2M



North Texas Municipal Water District Overview



NORTH TEXAS
MUNICIPAL
WATER
DISTRICT

BY THE NUMBERS

SERVE **90** COMMUNITIES



Service area of 2,200 square miles in 10 counties

Serving 1.6 million people in one of the fastest-growing regions in the country

DID YOU KNOW?

14

WATER PUMP STATIONS

6

WATER TREATMENT PLANTS
806+ MGD (million gallons/day) capacity

566
MILES

WATER TRANSMISSION PIPELINES



250+
MILES

LARGE-DIAMETER WASTEWATER PIPELINES

14

WASTEWATER TREATMENT PLANTS

151+
MGD

WASTEWATER TREATMENT CAPACITY
MGD (million gallons/day)




3 TRANSFER STATIONS
up to 3,295 tons of solid waste/day

800,000+ tons/year accepted at landfill



UEFIS Largest of Multiple NTMWD WW Service Areas



UEFIS Regional WWTPs Approaching Permitted Capacity

Wilson Creek RWWTP Capacity


- » 56 mgd annual average daily flow (AADF)
- » Expanding to 64 mgd AADF
- » TCEQ permit up to 64 mgd AADF

Rowlett Creek RWWTP

- » 24 mgd AADF


Combined future RWWTP capacity of 88 mgd AADF

Rowlett Creek RWWTP		
	Avg (mgd)	Peak (mgd)
Current	24	60
Permitted	24	120




Rapid Wastewater Flow Growth Projected

- Population of UEFIS projected to almost double by 2040
 - » ~600,000 to ~1.1 M
 - » Flows increasing quickly
- Growth concentrated in northern/eastern areas of UEFIS
 - » Served by Wilson Creek RWWTP
- Amended TCEQ discharge permit required for expansion beyond 64 mgd or new permit for new plant



Rapid Wastewater Flow Growth Projected

- Population of UEFIS projected to almost double by 2040
 - » ~600,000 to ~1.1 M
 - » Flows increasing quickly
- Growth concentrated in northern/eastern areas of UEFIS
 - » Served by Wilson Creek RWWTP
- Amended TCEQ discharge permit required for expansion beyond 64 mgd or new permit for new plant



Project Objective – Plan to meet 50-year UEFIS Regional WWTP Capacity Needs

Accommodate Growth:

- » *From 600,000 to 1M customers by 2040 in the UEFIS*
- » *Addition of future customers*



Maintain Lavon Lake water quality


- » *Meet future regulatory requirements*

Consider Biosolids Processing, Conveyance, Treatment implications on overall alternative capital/life cycle costs.

The Regional WWTP Conceptual Design to guide best value decisions for a “future proof” long-term strategy and an “actionable” short-term implementation plan.

Conceptual Design Study to Determine Path Forward to Address Capacity Needs

1. Expand Wilson Creek RWWTP – existing permitted discharge location
2. Expand Wilson Creek RWWTP – secondary permitted discharge location, Sister Grove arm
3. Design new RWWTP – Sister Grove arm discharge location




Existing and Planned Raw Water Supplies – Multiple Sources into Lavon Lake

Existing:


- Lavon Lake
- Lake Texoma
- Lake Tawakoni
- Chapman Lake
- Reuse/Wetland

Proposed:


- Lower Bois d'Arc Creek Reservoir



Project Study Area



Project Study Area



A defensible solution must consider wide range of scenarios

- » *“Future-proof” long-term strategy*
- » *“Actionable” short-term implementation recommendations*

Short-term and long-term growth

Impacts to and opportunities at existing facilities

Location for potential new facilities

Biosolids disposal

Conveyance impacts

Receiving water quality challenges

Future regulatory unknowns



Voyage™ model leverages various model inputs for system assessment

Voyage™

Water Balance Model

- Historical Data
- Scenario Management
- Operating Rules
- Water Balance Model
- Outputs



Cost Calc Workbook

- Output Data
- Capital and O&M Costs

Water Quality Analysis Model
(CEQUAL-W2, QUAL-TX, WASP)

Biosolids Model


Conveyance Model
(InfoSWMM)

RWWTP Process Model
(Pro2D)




NTMWD Voyage™ Model

- Customer Flows
- Collection & Transmission
 - » Gravity Sewers
 - » Force Mains
 - » Pump Stations
- Treatment
 - » Wilson Creek RWWTP
 - » Advanced Treatment
 - » New Water Resource Recovery Facility (WRRF)
- Lavon Lake water quality impacts on permitting/treatment requirements
- Biosolids processing facility impacts
- Capital/O&M costs



Tiered decision process to facilitate comprehensive evaluation of RWWTP Conceptual Design options

- Projected Flows – Current and Potential Future Customers (NTMWD)
- Discharge Location
- Current and Potential Future Water Quality Standards/ Discharge Permit Requirements (APAI)
- Treatment Technologies and Locations
- Biosolids Processing Technologies and Locations
- Non-cost criteria



Planning Approach and Key Issues



50-year planning horizon requires “Future-proof” planning methodology

- ◆ Scenario Planning – method of planning to evaluate a spectrum of future conditions, considering risk.
- ◆ **Scenario** – Unique combination of future conditions that must be met
- ◆ How do we identify the driving future conditions (scenarios) to be considered?




Step 1 – Identifying Project Drivers


Driving forces - external social, technological, environmental, economic, political and legal (STEEPL) trends likely to influence the strategy selected to meet the project objective.

- 💧 Population and economic growth
- 💧 Peaking factors in wastewater flow rates
- 💧 Per-capita wastewater flows
- 💧 Public support for facilities or projects
- 💧 Existing infrastructure nearing capacity
- 💧 Changing economic factors affecting future costs
- 💧 Increased cooperation with Member/Customer communities
- 💧 Lavon Lake water quality and effects on future permit requirements

Risk Mapping of Key Uncertainties Identifies Primary Drivers/Defines Scenario Matrix



Population and Customer Scenarios



Key Constituents for Permitting and Water Quality Management

💧 Dissolved Oxygen

- » *BOD*
- » *NH₃*


💧 Chlorophyll-a

- » *Total Phosphorus*

💧 TDS


Regulatory Condition Scenarios

- Primary goal of protecting Lavon Lake Water Quality
- Phosphorus assumed as proxy limiting parameter** by which suitability of treatment technologies for meeting potential for meeting future permit limits is assessed.




Treatment Approaches

Conventional BNR + Tertiary Polishing



Membrane Bioreactor



- A representative technology was selected for achieving each treatment objective for screening analysis – others are available
- P2HF:AADF ratio of 4.0
- EPA Class 1 reliability requirements
- Upgrade for Wilson Creek assumes addition of tertiary polishing for full plant flow, reusing existing filters

Scenario Matrix for 50-year Planning Assessment

Scenario 2 – Medium Population, Less Conservative P Limit

- Tier 1 and Tier 2 w/ medium projections
 - Projected 1.78 million people served
- Technology driven by use of tertiary clarification and filters

Scenario 1 – High Population, Conservative Effluent P Limit

- All Tiers w/ high projections
 - Projected 2.26 million people served
- Technology driven by use of membranes

Scenario 4 – Low Population, Less Conservative P Limit

- Existing Cities
 - Projected 1.3 million people served
- Technology driven by use of tertiary clarification and filters

Scenario 3 – Medium Population, Conservative Effluent P Limit

- Tier 1 w/ medium projections
 - Projected 1.61 million people served
- Technology driven by use of membranes

Biosolids Considerations

Two major treatment alternatives considered against all scenario conditions:

- » *Advanced digestion*
- » *Dewatering/landfilling*

Alternatives considered:


- » *Sludge processed on-site (Wilson Creek, Rowlett Creek, New WRRF (if applicable))*
- » *Sludge processed at Regional Facility*
 - Takes into account transfers of solids between plants (solids pipelines/pumping)

Updated capital/O&M costs from 2013 Biosolids Master Plan (power, polymer, trucking)



Alternative Assessment

- Assessed 29 total individual alternatives for each year of the planning horizon and for each of the 4 planning scenarios
 - 4 Major WWTP Site/Discharge Options Considered
 - 3 Discharge locations
 - 4 Biosolids Processing Alternative Elements
- Voyage model used in assessment and generated life cycle costs (LCC)




General WRRF Considerations and Non-Cost Criteria


Non-cost criteria combined with alternative cost results to determine best-value solutions

Non-cost criteria considered:

1. Flexibility to meet future regulatory and population requirements
2. Operational flexibility
3. Watershed protection
4. Community impact
5. Facilitates resource recovery (energy and nutrients)



Benefit-cost analysis identifies best balance of monetary and non-monetary criteria




Assessment Results




Best Performing Alternatives, Total System Life Cycle Cost Only


- Wilson Creek Expansion/Existing Discharge alternatives least expensive
- Followed closely by alternatives at Greenfield site "B"



Top-Performing Alternatives – Benefit-Cost Scores



Scenario 1, 2070



Scenario 2, 2070

Top-Performing Alternatives – All Scenarios

Top-performing alternatives across full range of future conditions considered (scenarios):

Alternative	Plant Location/Solids Processing
16B	New WRRF Site B /Landfill from site generation
19B	76 MGD to WC WWTP, remainder to New WRRF Site B/Landfill from site generation
9A	New WRRF Site A/Landfill from site generation
20B	76 MGD to WC WWTP, remainder to New WRRF Site B/ WC offsite dewatering with landfill, remainder landfill from site generation

Wilson Creek RWWTP Expansion(s)

(not recommended)

- 💧 Lake water quality modeling indicates 76 mgd is possible, but not at existing permit limits
 - » *additional process improvement likely required to reliably meet DO standard*
 - » *% blend/mixing in East Fork Arm*
- 💧 Full Expansion to meet 2070 projection, all Tiers, high growth – additional 120 mgd
 - » *not feasible long-term due to water quality, land needs, community concerns; relocated discharge cost prohibitive*
- 💧 Projections with new customers indicate potential for near simultaneous partial expansion/new WWTP permitting/implementation

Alternatives Recommended for Further Evaluation/Current Status

Top 2 alternatives

- » Site A
- » Site B

NTMWD in property acquisition phase

- » *Some conceptual design comparison of alternatives to facilitate acquisition*
 - Conceptual costs
 - Layouts
 - Land acquisition requirements

Additional WQ modeling (creek, lake)

Complete conceptual design study report following site selection/WQ modeling

Meet with TCEQ/USACE to vet findings/approach

NTMWD preparing permit application



Questions?

