



How Innovative Tools and Site Specific Data Helped Save \$20M in WWTP Wet Weather Upgrades

TACWA - January 25, 2019

Hazen

Project Objective and Challenges

Overall: Develop robust and operationally flexible treatment configuration to treat both average and wet weather flows at a sustainable cost

Challenges:


- Site constraints
- Reliability through redundancy
- Peaking factors
- Operation year round



Plant Overview and Project Approach



Rowlett Creek RWWTP Liquid Process Post-Phase I




Site Overview



Site Overview

City of Plano Los Rios Golf Course



Privately-Owned Soccer Complex



Current Effluent Discharge Permit Flow

- TPDES Permit No. WQ0010363001
- Average Annual Flow = 24 mgd
- Current Peak 2-Hr. Flow = 60 mgd
- Phase I Peak 2-Hr. Flow = 77.5 mgd
- **Phase II Peak 2-Hr. Flow = 95 mgd**
- **Ultimate Peak 2-Hr. Flow = 120 mgd**




Current Effluent Discharge Limitations

Effluent Characteristic	Daily Avg. mg/L (ppd)	7-day Avg. mg/L	Daily Max mg/L	Single Grab mg/L
Carbonaceous BOD₅				
December – March	7 (1,401)	11	17	30
April - November	5 (1,001)	10	20	30
Total Suspended Solids				
December – March	12 (2,402)	20	40	60
April - November	5 (1,001)	10	20	30
Ammonia Nitrogen				
December – February	3 (600)	6	10	15
March	2 (400)	5	10	15
April - November	1.2 (240)	5	10	15
Total Phosphorus	1.0 (200)	N/A	Report	N/A
Sulfate, Total Dissolved Solids and <i>E.Coli</i> not shown.				



Project Approach

Whole plant perspective



Establish the “true” peak capacity of existing




Evaluate alternatives



Defining Treatment Capacity



Defining Treatment Capacity



- Hydraulic loading rate
- Solids loading rate
- Contact time
- Pump capacity
- Velocity and pipe size



Defining Treatment Capacity – Secondary Process



Process and Treatment Factors

- Influent characteristics
- Discharge permit
- Climate / temperature
- Configuration

Define Biomass Inventory

Solids Separation


- Multi-phase hydrodynamics
- Settling characteristics
- Configuration
- Flow distribution

Define Limitations

Capacity



Defining Capacity – Challenge





**State-of-the-art tools
provide confident and
reliable solutions**

**Whole Plant
Hydraulic Models**

**WWTP
Process
Models**

**CFD
Clarifier
Models**


**Capacity
Analysis and
Optimization**




Applying State-of-the-Art Tools to Rowlett Creek RWWTP



**State-of-the-art tools
provide confident and
reliable solutions**



**WWTP
Process
Models**



**CFD
Clarifier
Models**





**Capacity
Analysis and
Optimization**







Process Model Development and Calibration





Rowlett Creek RWWTP Secondary Clarifiers





What's so complicated about a clarifier?

Types of Settling

Non-settleable

Discrete settling (Type I)

Flocculent settling (Type II)

Hindered or zone settling (Type III)

Compression (Type IV)

Empirical Definitions

$$V_S = V_0 \cdot e^{(-K \cdot X_{TSS})}$$

$$C = a + (C_0 - a) \cdot e^{-k \cdot t \cdot X}$$


$$n_t = \frac{K_B \cdot G}{K_A} + \left(n_o - \frac{K_B \cdot G}{K_A} \right) \cdot e^{-K_A \cdot X \cdot G \cdot t}$$

$$\frac{dn}{dt} = K_b \cdot X \cdot G^2 - K_a \cdot X \cdot n \cdot G$$

and more...


There are methods to quantify and tools to apply





Secondary Clarifier Field Sampling





Applying Clarifier CFD Modeling


MLSS and Sludge Blanket Concentration (kg/m³)




Velocity Magnitude and Vector (fps)



- 2Dc CFD models developed for 4 secondary clarifier configurations
- Calibrated and validated with field data






A calibrated simulation! Is it any good?

Rowlett Creek Regional Wastewater Treatment Plant
Existing SC 2
SOR = 980 gpd/sf
MLSS = 2,370 mg/L


Results (FINAL TIMESTEP)
ESS = 14.6 mg/L
RAS SS = 8,830 mg/L
SBH = 8.9 ft

0.5 ft/s





0 Minutes







Observed – Sludge Blanket Height






Validated – Sludge Blanket Height




Tying the Tools Together for Dynamic Analysis



**Capacity
Analysis and
Optimization**



Existing Asset Process Capacity without Improvements



Average surface overflow rate of 1,350 gal/d/sf vs 1,250 gal/d/sf (design)



Existing Asset Wet Weather Capacity without Improvements




Unit Process	Peak Flow (MGD)		
	Train A	Train B	Total
Primary Clarifiers	35.0	25.0	60
Secondary Clarifiers	33.0	31.4	64.4
Filters	26.8	19.0	45.8
Chlorine Contact	30.5	25.0	55.5
Phase I MBR	17.5	-	17.5

Secondary Treatment Capacity = 81.9 MGD




Train A Current Flow Configuration





Phase II Storm (95 MGD) - Flow




Train	Flow, mgd	% of Total
Train A Existing	46.1	49%
Train A MBR	17.5	18%
Train B	31.4	33%
Total	95	100%





Phase II Storm (95 MGD) – Current Configuration




Secondary Clarifier Performance at **SVI 60 mL/g**



SCs 5 and 6 Clarifiers
SVI = 60 mL/g (High Vo Factor)
Max SOR = 1,640 gpd/sf
No Step Feed Option

Results
Max ESS < 10 mg/L



Capable of passing 95 MGD w/ average settling




Secondary Clarifier Performance at SVI 100 mL/g



Secondary Clarifiers 5 & 6
SVI = 100 mL/g (High Vo Factor)
Max SOR= 1,640 gpd/sf
No Step Feed Option

Results
Max ESS > 60 mg/L



Poor settling is an issue



Implementation of Step Feed as a Wet Weather Strategy



Compare impact of influent feed location:

- No Step Feed, Current Configuration
- 50% Step Feed
- Contact Stabilization

MLSS



Clarifier Solids Loading Rate




Clarifier Overflow Rate






Train A Flow Schematic – Current Configuration






Train A Flow Schematic – Step Feed





Phase II Storm (95 MGD) – MLSS with 50% Step Feed




Secondary Clarifier Performance at SVI 100 mL/g



Secondary Clarifiers 5 & 6
SVI = 100 mL/g (High Vo Factor)
Max SOR= 1,640 gpd/sf
50% Step Feed Option


Results
Max ESS < 30 mg/L



Poor settling is no longer an issue



Existing Process Capacity with Step Feed Flexibility



Average surface overflow rate of 1,650 gal/d/sf vs 1,250 gal/d/sf (design)





Existing Process Capacity with Step Feed Flexibility

Unit Process	Peak Flow (MGD)		
	Train A	Train B	Total
Primary Clarifiers	35.0	25.0	60
Secondary Clarifiers	46.3	31.4	77.7
Filters	26.8	19.0	45.8
Chlorine Contact	30.5	25.0	55.5
Phase I MBR	17.5		17.5

**Secondary
Treatment
Capacity =
95.2 MGD**



Alternatives for Peak Flow Expansion



Short-Listed Alternatives

Base Case – MBR conversion


Alternative 1 – Step feed configuration

Alternative 2 – Converting Train A to biological high rate clarifier (bio-HRC) and Train B to step feed

Alternative 3 – Combination of step feed and bio-HRC for Train A and Train B step feed




Base Case – Site Plan



By others



Alt. 1: Step Feed = 120 MGD – Operation During Peak




Alt. 2 Biological High Rate Clarification

High Rate Physical-Chemical Treatment

Polymer + Coagulant

Ballast (Microsand)


Lamella Plate or Tube Settlers



Kruger BioActiflo®




Alt. 2: HRC = 120 MGD – Operation During Peak



* With Step Feed



Alt. 3: HRC/Step Feed Combo = 120 MGD – Operation During Peak



* With Step Feed



Phase III Liquid Process Cost Summary

Shortlisted Alternatives	Capital Cost	20-Year O&M Present Value	Life Cycle Cost 20-Year NPV
Base Case: MBR Conversion	\$81M	\$61M	\$142M
1: Step Feed and Additional Clarifier	\$60M	\$28M	\$87M
2: Train A - High Rate; Train B - Step Feed	\$57M	\$41M	\$98M
3: Train A - Hybrid (High Rate and Step Feed); Train B – Step Feed	\$63M	\$33M	\$97M

\$21M savings
in liquid process improvements with
recommended alternative



Conclusions

- Re-rating capacity is site-specific
- Build confidence through dynamic evaluation tools
- Account for year-round operation and flexibility
- Whole-plant perspective



Special Thanks and Acknowledgments



Rowlett Creek RWWTP Operations Staff: Brent Lorance, Joshua Boyd and all the operations staff

NTMWD Laboratory: Kelly Harden and staff

NTMWD Project Staff: Jenna Covington, Bret Ellis, Morgan Dadgostar, Phil Spitzer and Shela Chowdhury



Hazen and Sawyer: Chamindra Dassanayake, Alonso Griborio, Joseph Rohrbacher and the Sweat Crew



Project Partner: Gupta and Associates

Questions



Donna Long, PE
Wastewater Program Manager
dlong@ntmwd.com
(469) 626-4719



Brandt Miller, PE
Associate
Wastewater Practice Lead for Texas
bmiller@hazenandsawyer.com
(469) 250-3784



Bullpen

Settling Tank (SST) models

Four Types of SST Models are Generally Available:

Zero-Dimensional (0-D)

Mass Balance +/- Heuristics

Hazen (1904), Camp-Dobbins (1944, 1946)

One-Dimensional (1-D)

Layered Models

Vesilind, State-Point, Drift-Flux Model (BioWin)

Two-Dimensional (2-D)

Computational Fluid Dynamics
(CFD)

Larsen (1977), LaRock; McCorquodale et al;
Rodi et al (1980-2000); Griborio and
McCorquodale (2004)

Three-Dimensional (3-D)

CFD

Richardson (2000), CCNY, Hazen (2017)



SC 1 and 2 Stress Testing Observations



SC 1




SC 2






Train A Flow Schematic – Contact Stabilization



Phase II Storm (95 MGD) – MLSS with Contact Stabilization



Δ MLSS = 1,400 mg/L


Δ MLSS = 1,000 mg/L

— Train A MLSS — Train B MLSS





Phase II Storm (95 MGD) – Effluent $\text{NH}_3\text{-N}$



— Train A — Train B — Combined Effluent
— Permit Daily Max - Winter — Permit Daily Avg - Winter



Clarifier Capacity Analysis Results – Contact Stabilization



Secondary Clarifiers 5 & 6
SVI = 100 mL/g (High Vo Factor)
Max SOR= 1,640 gpd/sf
100% Step Feed Option

Results
Max ESS < 20 mg/L

