



EPA's Blending Policy and the Future of Wet Weather Management at WRRFs

Murali Erat, PE



July 26, 2019

Outline

- **EPA's Blending Policy**
 - Background
 - Regulatory History & Upcoming Policy
- **Case Study – Wet Weather Blending**
 - **Port Arthur Main WRRF - Background**
 - Current Treatment Process
 - Wet Weather Management Approach
 - **Pilot Testing of Cloth Media Filtration System**
 - AquaPrime Filtration System
 - Pilot Testing Results
 - **Conclusion**

EPA's Blending Policy

Background


- Clean Water Act (CWA) – Forbids Discharge of Any Pollutant to Navigable Waters from Any Point Source
- National Pollutant Discharge Elimination System (NPDES) Permit
- Effluent Limitations Apply at **“End-of-Pipe”**
- Secondary Treatment Regulations **Do Not Specify Type of Treatment Process**



EPA's Blending Policy

Bypass (40 CFR Section 122.41 (m))


- Definition: Intentional **diversion** of waste streams from any portion of treatment facility
- Bypass is **Prohibited** unless unavoidable to prevent loss of life, personal injury, severe property damage, or no other feasible alternative



EPA's Blending Policy

Blending

- Definition: Channeling a portion of the “peak wet weather flows” through non-biological unit and re-combining with flow from biological secondary treatment before disinfection and discharging.




Blending = Prohibited Bypass

In Separate Sanitary Sewer Systems

EPA's Blending Policy

Blending

- Excessive Peak Flows During Wet Weather Events
- Adverse Effect on Biological Secondary Treatment Unit:
 - Exceed capacity
 - Solids “wash-out”
 - Sensitive to Large Deviation in Flow Volume
- Blending Technologies:
 - More Effective than Biological Processes in Treatment of Peak Flows
- Reduce Sanitary Sewer Overflows




EPA's Blending Policy

EPA Issues Proposal
"Blending is Not a
Prohibited Bypass"

- Blended flow **must meet final effluent limitations**
- Must provide **at least primary clarification**
- Blending only when flow **exceeds biological treatment unit capacity**
- Collection system be properly operated and maintained

2003



2005

Prior to 2003 EPA's Policy
on Prohibition of
Blending is Unclear

EPA Abandons 2003 Proposal

EPA's Blending Policy

Iowa League of Cities
Request EPA clarification
for use ACTIFLO for peak
flow treatment





March 2011

EPA Issues Letter Declaring:

- Use of ACTIFLO – Prohibited Bypass
- ACTIFLO is not a satisfactory secondary treatment unit

September 2011



ACTIFLO: Physical/Chemical Secondary Treatment System

EPA's Blending Policy

Iowa League of Cities Files Lawsuit Against EPA in Court of Appeals 8th Circuit



United States Court of Appeals
For the Eighth Circuit

No. 11-3412

Iowa League of Cities

Petitioner

v.

Environmental Protection Agency

Respondent

Petition for Review of an Order of the
Environmental Protection Agency


Submitted: November 13, 2012

Filed: March 25, 2013

Before SMITH, BEAM, and GRUENDER, Circuit Judges.




EPA's Blending Policy



EPA's Blending Policy

US 8th Circuit Court Ruling on Blending

- Blending \neq Prohibited Bypass
- Use of non-biological secondary treatment of peak flow is legal




Ruling Applies Only in US 8th Circuit States:
Arkansas, Iowa, Minnesota, Missouri,
Nebraska, North Dakota, South Dakota

EPA's Blending Policy

Opponents Argument Against Blending

- Allowing blending undermines incentive to reduce I/I in collection system
- Public health impact:
 - A few studies show higher levels of some pathogen (Giardia and Crypto) during blending compared to dry weather events



News Releases from Headquarters > Water (OW)

EPA Announces Effort to Update Wet Weather Regulations for Wastewater Treatment Plants

04/17/2018

Contact Information:
EPA Press Office (press@epa.gov)

WASHINGTON — Today, the U.S. Environmental Protection Agency (EPA) announced it will be reaching out to states, local communities, and stakeholders as the Agency begins a new rulemaking process to provide certainty surrounding the use of "blending" by wastewater treatment plants.


Peak Flows at Sewage Treatment Plants

Peak Flows Management Rule | Background | Forum on Public Health Impacts

Peak Flows Management Rule


In April 2018, EPA announced a new rulemaking to look at issues associated with the management and treatment of peak flows during wet weather events at publicly owned treatment works (POTWs) with separate sanitary sewer systems. Through this rulemaking, EPA will evaluate changes to its National Pollutant Discharge Elimination System (NPDES) regulations to establish a transparent and lasting framework to permitting peak flow management options.

EPA Announces New Rulemaking for Wet Weather Management



Stakeholder Meetings/Public Listening Sessions
(EPA, NGOs, Utilities, NACWA, WEF, Engineers, Public Health Experts)

Proposed Draft Rule on Blending



Final Rule on Blending

EPA's Blending Policy

What can we expect in the new blending policy?

- Clarification on the definition of bypass and blending
- Allow blending of peak flows in sanitary sewer systems
- Solids removal and disinfection will be required for blended flow
- Blended effluent must limit final permit limits
- Compliance measured at final outfall and not at any point within the treatment plant





Case Study: Use of Cloth Media Filtration Systems for Wet Weather Management

CITY OF PORT ARTHUR, TEXAS


MAIN WRRF



City of Port Arthur – Main WRRF


- Original Build – **1960**
- Major Improvements – **1981, 1991**
- Average Daily Flow (ADF) – **9.2 MGD**
- 2-hour Peak Flow – **45 MGD**
- Discharge Limits:
 - BOD – **20 mg/L**
 - TSS – **20 mg/L**
 - Enterococci – **35 CFU**
- Main Treatment Process:
 - **Primary Clarification**
 - **Trickling Filter/Activated Sludge**
 - **Chlorine Disinfection**
- Wet Weather Process:
 - **Clarification**
 - **Chlorine Disinfection**

Main WRRF – Current Treatment Process





Current Wet Weather Management



- **Catastrophic Failure of Stormwater Clarifier** – due to Failure of Hydrostatic Pressure Relief Valve

Port Arthur Main WRRF

Wet Weather Management Approach


Avg. Daily Flow – 9.2 MGD 2-hr Peak Flow – 45 MGD

Flows > 15 MGD



Stormwater Clarifier


Clarification



AquaPrime® Filters

Filtration

AquaPrime® Filtration System




Courtesy: Aqua-Aerobic Systems, Inc.




Implementation of **AquaPrime®** Filtration system at Port Arthur Main WRRF

Main WRRF Improvements – Initial Phase



Flow stream to AquaPrime® Filters: **Screened Raw Influent**

Main WRRF Improvements – Final Phase



Flow stream to AquaPrime® Filters: **TF Eff., Final Clarifier Eff.**

AquaPrime® Filtration System – Pilot Testing

Pilot Testing: Ten (10) consecutive weeks




AquaPrime® Filtration System – Pilot Testing

May 14 – July 20, 2018

Week No.	Flow Stream	
1	Primary Clarifier Effluent	Wet Weather Mode
2	Primary Clarifier Effluent	
3	Primary Clarifier Effluent Trickling Filter Effluent (First Stage)	
4	Trickling Filter Effluent (First Stage)	
5	Trickling Filter Effluent (First Stage) Trickling Filter Effluent (First Stage) + Secondary Effluent	
6	Trickling Filter Effluent (First Stage) + Secondary Effluent Secondary Effluent	Tertiary Treatment Mode
7	Secondary Effluent	
8	Raw Influent (Screened)	Primary Treatment Mode
9	Raw Influent (Screened) + ACH	
10	Raw Influent (Screened) + ACH Primary Effluent + ACH/Ferric	

AquaPrime[®] Pilot Testing Results – Conclusion




- ✓ Better performance in BOD, TSS removal than clarifier
- ✓ Consistent effluent TSS limit even at high loadings
- ✓ Consistent performance in primary filtration, wet weather mode and tertiary filtration modes
- ✓ Performance enhanced with small dose of coagulant (ACH or Ferric)

Flow Stream	% BOD Removal (Avg.)	Avg. Effluent BOD Conc. (mg/L)	% TSS Removal (Avg.)	Avg. Effluent TSS Conc. (mg/L)
Raw Influent	44%	26	63%	23
Raw Influent + ACH	54%	20	78%	12
Primary Effluent	30%	61	40%	29
Primary Effluent + ACH	56%	12	67%	15
Trickling Filter Effluent	29%	21	53%	8
Secondary Effluent	33%	4	92%	2
TF + Sec. Effluents	42%	11	80%	4

Port Arthur Main WRRF Improvements

Project Timeline





Questions?

Murali Erat, PE

Freese and Nichols, Inc.

Murali.Erat@freese.com

(832) 456-4709