



Optimizing Operations to Reduce WRRF Costs:

A Case Study of the City of Richmond

Dan Olson | Garver



Richmond is located 15 miles southwest of Houston on the Brazos River and serves a population ~24,000

Customer Base

- Residential – 87%
- Commercial/Institutional – 13%







The Richmond Regional WWTTF is a Conventional Activated Sludge Treatment plant permitted for 3 MGD

Reuse System Capacity 1.5 MGD

An assessment of the Richmond WWTF



Garver's study addressed two main objectives



OBJECTIVE #1:
**Identify solutions to
eliminate foaming issues**

Multiple factors were investigated to identify the root cause of foaming




- Low DO
- High DO
- Chlorinated mixed liquor return
- Surfactants
- Toxicity
- Nutrient Deficiency
- Filaments (Low F:M)
- High Oil & Grease

Historical data was used to pinpoint the cause(s) of foam at the Richmond Regional WWTF


	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1		Aeration Basin Volume	1,343,920			gallons											
2		Aeration Basin Volume	179,668			cu.ft.				Avg. Inf BOD	197						
3		Total Clarifier Volume	1,066,225			gallons				Avg. Inf NH3	30						
4		Total Digester Volume	1,008,872			gallons				Avg. Inf TSS	232						
5																	
6						Permit Effluent BOD (mg/L):	10			Permit Effluent NH3-N (mg/L):	3			Permit Effluent TSS (mg/L):	15		
7		Date	Permit Flow (MGD)	Avg. Flow (MGD)	Permit Flow (MGD)	Influent BOD (mg/L)	Effluent BOD (mg/L)	Average Effluent BOD (mg/L)	Permit Effluent BOD (mg/L)	Influent NH3-N (mg/L)	Effluent NH3-N (mg/L)	Average Effluent NH3-N (mg/L)	Permit Effluent NH3-N (mg/L)	Influent TSS (mg/L)	Effluent TSS (mg/L)	Average Effluent TSS (mg/L)	Permit Effluent TSS (mg/L)
8	1	3/29/2018	1.988	1.404134	3		2	2.8492537	10		4.75	0.33014925	3		2.8	4.48552239	
9	2	3/28/2018		1.404134	3			2.8492537	10			0.33014925	3			4.48552239	
10	3	3/27/2018	1.634	1.404134	3	198	6.8	2.8492537	10	35.7	4.23	0.33014925	3	2400	5.4	4.48552239	
11	4	3/22/2018	1.276	1.404134	3		2	2.8492537	10		2.16	0.33014925	3		7.2	4.48552239	
12	5	3/20/2018	1.325	1.404134	3	173	3.6	2.8492537	10	4.65	2.87	0.33014925	3	70	2.2	4.48552239	
13	6	3/16/2018		1.404134	3			2.8492537	10			0.33014925	3			4.48552239	
14	7	3/15/2018	1.257	1.404134	3		2.5	2.8492537	10		0.1	0.33014925	3		6.8	4.48552239	
15	8	3/13/2018	1.237	1.404134	3	186	2	2.8492537	10	28.8	0.1	0.33014925	3	107	4.2	4.48552239	
16	9	3/12/2018		1.404134	3			2.8492537	10			0.33014925	3			4.48552239	
17	10	3/8/2018	1.583	1.404134	3		3	2.8492537	10		0.1	0.33014925	3		1.32	4.48552239	
18	11	3/6/2018	1.755	1.404134	3	221	2	2.8492537	10	18.1	0.1	0.33014925	3	308	3.6	4.48552239	
19	12	3/1/2018	1.114	1.404134	3		2.1	2.8492537	10		0.1	0.33014925	3		6	4.48552239	
20	13	2/27/2018	1.63	1.404134	3	364	2.3	2.8492537	10	27.8	0.1	0.33014925	3	90	4.4	4.48552239	
21	14	2/26/2018		1.404134	3			2.8492537	10			0.33014925	3			4.48552239	

Additional
sampling was
recommended to
increase data
resolution




Analysis & Findings


Flow to the WWTF was within the permitted design capacity of 3 MGD




Influent BOD loading was also within the design capacity of the plant



Average MLSS and MLVSS were relatively high for the application




The moderate BOD loading combined with high MLVSS resulted in a low F:M ratio




Chlorine feed rate was high to combat poor distribution of chemical in the CCBs

Chlorine Residual




**Microscopy
analysis
suggested the
most likely cause
of foam was
filaments**



Recommendations

Immediate recommendations focused on removing foam-causing substances from the basins

Divert Scum Line to Digesters



Waste Solids to Reduce SRT and Increase F:M Ratio



The result of these changes was immediate improvement in foam accumulation



OBJECTIVE #2

**Process optimization focused
on lowering the overall
operating cost to the City**



Multiple plant process units were identified for improved consistency through process control



Aeration

Blower Operation on D.O. Control



Clarifiers

Waste Continuously to Maintain MLSS



Chlorine Contact

Improve Chemical Mixing and Avoid Over-Feeding



Solids Processing

Increase Efficiency of BFP

Plant operating costs were broken down into three categories



Chemicals

- Sodium Hypochlorite
- Sodium Bisulfite
- Polymer
- Defoamer



Electricity



Sludge

- Dry Sludge Hauling
- Wet Sludge Hauling


Prior to the study, the plant's operating budget was dominated by chemical costs



Electricity
34%




Sludge
14%




Chemicals
52%




Eliminating the foam reduced the proportion of operating costs that go to chemical purchases



More importantly, it significantly reduced the total annual operating costs of the plant




Electricity costs decreased with blower controls tied to dissolved oxygen sensors




A majority of chemical costs were associated with defoamer, which was eliminated

Average Monthly Chemical Costs




Sludge hauling costs increased as a result of the increased solids wasting from the aeration basins

Sludge Hauling Costs




Sludge hauling costs increased as a result of the increased solids wasting from the aeration basins

Sludge Hauling Costs




Sludge hauling costs increased as a result of the increased solids wasting from the aeration basins

Sludge Hauling Costs




Sludge hauling costs increased as a result of the increased solids wasting from the aeration basins

Sludge Hauling Costs




Wet sludge hauling occurred during BFP outages or when solids wasting exceeded BFP capacity

Sludge Hauling Costs



Wet sludge hauling occurred during BFP outages or when solids wasting exceeded BFP capacity

Sludge Hauling Costs



Logistics issues
with the current
sludge hauling
configuration limit #
of loads/day




- 1 Belt Filter Press
- 1 Conveyor
- 1 Dumpster
- *Inability to fill more than one dumpster at a time*

Conclusions & Next Steps


Plant-wide operating cost reductions were achieved with minimal capital investment

Monthly Operating Costs



The study procedure identified targets for additional cost reduction

Monthly Operating Costs



Garver updated plant SOPs and provided an operator dashboard for ease of implementation

Richmond Regional WWTF WAS & RAS																				
Instructions: Enter values in grey boxes. Fixed values are indicated by maroon cells. Spreadsheet calculates values in navy boxes																				
Flow	1.5 MGD		Calculated RAS Flow	1.46 MGD		<table border="1"> <thead> <tr> <th>Process Control Parameter</th> <th>Typical Range</th> </tr> </thead> <tbody> <tr> <td>F:M Ratio</td> <td>0.05 - 0.15</td> </tr> <tr> <td>BOD Loading (lb/day/1000 ft³)</td> <td>10 - 25</td> </tr> <tr> <td>Aeration Basin HRT (hours)</td> <td>18 - 24</td> </tr> <tr> <td>Aeration Basin SRT (days)</td> <td>20 - 30</td> </tr> <tr> <td>Recycle Ratio</td> <td>0.75 - 1.50</td> </tr> <tr> <td>BOD Removal Efficiency</td> <td>75 - 90%</td> </tr> </tbody> </table>	Process Control Parameter	Typical Range	F:M Ratio	0.05 - 0.15	BOD Loading (lb/day/1000 ft ³)	10 - 25	Aeration Basin HRT (hours)	18 - 24	Aeration Basin SRT (days)	20 - 30	Recycle Ratio	0.75 - 1.50	BOD Removal Efficiency	75 - 90%
Process Control Parameter	Typical Range																			
F:M Ratio	0.05 - 0.15																			
BOD Loading (lb/day/1000 ft ³)	10 - 25																			
Aeration Basin HRT (hours)	18 - 24																			
Aeration Basin SRT (days)	20 - 30																			
Recycle Ratio	0.75 - 1.50																			
BOD Removal Efficiency	75 - 90%																			
Aeration Basin MLSS	5,100 mg/L		Calculated WAS Flow	0.06 MGD																
Influent TSS	230 mg/L		WAS Daily Loading	2,546 lb/day																
RAS MLSS	5,000 mg/L		Calculated SRT	23 Days																
Effluent TSS	13 mg/L		Recycle Ratio	1.0																
Target SRT	25 days		Relevant Equation(s):	$SRT, \text{ days} = \frac{(\text{Aeration Basin Volume, MG}) * (8.34) * (\text{Aeration Basin MLSS, } \frac{\text{mg}}{\text{L}})}{(\text{WAS Flow, MGD}) * (8.34) * (\text{WAS Suspended Solids, } \frac{\text{mg}}{\text{L}})}$																
Recorded WAS	0.06 MGD																			
Aeration Basin Volume	1.34 MG																			

Acknowledgments

- Howard Christian, City of Richmond
- Mike Moody, City of Richmond
- Gary Sober, Garver



Questions?

DAN OLSON

(713) 395-4277

DNOLSON@GARVERUSA.COM

